

MNV-W-16-01

**Jean Jewell**

---

**From:** Dawn Gneiting <newdawn62@gmail.com>  
**Sent:** Friday, October 07, 2016 8:22 AM  
**To:** Jean Jewell; Terri Carlock; Rochelle.Mason@deq.idaho.gov  
**Subject:** Morning View Water Co. Set Back

Yesterday afternoon a small part failed and the security system did not pick it up. The result was that the message to the new well was "low pressure". The well pumped for several hours before we found the problem. It was running at 130 pounds of pressure. The high pressure blew out a pipe in the old well. Water shot up damaging the ceiling, insulation, dry wall and water was two feet deep when the door was opened. The engineer came, and we worked until the water leak was turned off. The whole system was shut off and the failed part was changed in about two hours.

Clean up begins this morning. We are assessing the structural damage to the old well house. The old wells are turned off for repair but the new well is on line and working well. We will be conferring with the engineer, the security system people and the 3h Construction Co. who build the system to ascertain if safeguards were programmed and included to alert us to high pressure and low pressure. A water test has been taken per DEQ's protocol.

We do not know what the repair costs will be but will keep you updated.

Please call if you have questions or directions 745 0029

Thanks, Nolan Gneiting

RECEIVED  
2016 OCT 11 PM 2:37  
IDAHO PUBLIC  
UTILITIES COMMISSION